

## Electrical Cord Requirements For State Horse Show

110 Volt outlets for tack trailers - Cord must be a #12 Gauge Heavy duty cord, 3 wire grounded connector on each end. Ground **MUST** be attached.

110 Volt outlet for Campers - Cord must be a #10 Gauge Heavy duty cord, 3 wire grounded connector where not hard wired into trailer. Ground **MUST** be attached. The proper UL listed adapter must be used when adapting to different plugs.

220 Volt outlet for Campers - Cord must be a #8 Gauge Heavy duty cord, 4 wire grounded connector where not hard wired into trailer. Ground **MUST** be attached. The proper UL listed adapter must be used when adapting to different plugs.

All Cords - Must be in good condition, no tape, electrical joints, or additions to cord in anyway. Maximum length of cord should be 100', most electrical outlets are within 50' or less of all camping spots. If cord used is longer than the distance to the outlet, it must be laid out, not left rolled up in or under camper. State Fairgrounds electrician has final say in all cord connection.

Fairgrounds Electrician